



Duplin County Emergency Management

<https://www.duplincountync.com/fire-emergencymanagement/>

209 Seminary Street • Kenansville, NC 28349

Tel 910-296-2160 • Fax 910-296-2164

Brian Matthis, Emergency Management Coordinator

Logan Blizzard, Deputy Fire Marshal

Chris Vernon, 911 Communications Director

Brittany Malone, Administrative Support Specialist

Matthew Barwick, Director/Fire Marshal

Date: December 5, 2024

RE: RFP Questions - Duplin County Emergency Management/ Duplin County Schools
Kenansville Elementary School Backup Generator

Kenansville Elementary School Backup Generator

Q: E101 drawing 101.2 shows Panel KES2 being fed from Panel M2A as well as the note in the panelboard schedule. However, the line diagram on E102 drawing 102.2 shows the panel being fed from Panel 2PA. Panel M2A is the only existing panel with space and I want to confirm that is the intended panel to be used.

A: Feed panel KES-2 from panel M2A as indicated on the panel schedule, NOT as shown on the riser diagram.

Q: E101 panelboard schedule shows a 100 Amp main circuit breaker panel for both KES 1 and 2, while the E102 drawing 102.2 line drawing shows a main lug only panel to be used. By code, the MLO panel is cheaper and compliant. I would like to confirm that this is what is to be used.

A: Both KES-1 & KES-2 can be Main Lug Only (MLO) panels as indicated on the riser. Disregard the "MCB" on the panel schedules.

***Note: Revised plans addressing these corrections can be made available as requested to be rendered concurrent with an awarded contract for services.*

